



AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005

4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

To,

Date: 27-01-2020

ASSISTANT EXECUTIVE ENGINEER

VIDYARANYAPURA SUB DIVISION

BBMP

BANGALORE

Dear Sir,

Sub: M/s. Civil Pro Services for the work of IMPROVEMENTS AND ASPHALTING TO ROADS AT 6TH MAIN DHANALAKSHMI LAYOUT IN WARD NO.09 (VIDYARANYAPURA) VIDYARANYAPURA SUB DIVISION.

Ref: 1. Work Order No: BBMP/EE/BTP/WO/173/2019-20

2. Job code: 009-20-000008

We are here with forwarding to Sri. M/s. S.L.V Constructions Prop. Sri. Namith B #83, 1st Floor, 8th Main Road BEML Layout, Basaveshwaranagara Bangalore-560079. First and Final Bill duly verified and certified that the Work is satisfactory and for a Gross Value of RS.8,55,019.00/- (RS. Eight Lakhs Fifty Five Thousand and Nineteen Only).

Thanking you,

Yours faithfully,

For Civil Pro



R. KARTHIK RECHAN
AUTHORIZED SIGNATORY
CIVIL PRO



QC ABSTRACT

NAME OF WORK: Improvements and Asphalting to Roads at 6th Main Dhanalakshmi Layout in Ward No.09 (Vidyaranyapura) Vidyaranyapura Sub Division.

SL NO	Item Of Work	Name of Test	Frequency of Test/Quantity	Executed Quantity	Number of Tests Required	Number of Tests Conducted
Materials						
1	Cement	Fineness by dry sieving	One Test		1	1
		Fineness by Air permeability method	One Test		1	1
		Density	One Test		1	1
		Standard Consistency	One Test		1	1
		Initial Setting time	One Test		1	1
		Final Setting time	One Test		1	1
		Soundness (Le Chatelier's Method)	One Test		1	1
		Compressive Strength	One Test		1	1
2	Coarse aggregate(40 mm down size)	SIEVE ANALYSIS	One Test		1	1
		Flakiness Index	One Test		1	1
		Elongation Index	One Test		1	1
		Specific Gravity	One Test		1	1
		Bulk Density(Loose)	One Test		1	1
		Bulk Density(Compacted)	One Test		1	1
		Water Absorption	One Test		1	1
		SIEVE ANALYSIS	One Test		1	1
3	Coarse aggregate(20 mm down size)	Flakiness Index	One Test		1	1
		Elongation Index	One Test		1	1
		Specific Gravity	One Test		1	1
		Bulk Density(Loose)	One Test		1	1
		Bulk Density(Compacted)	One Test		1	1
		Water Absorption	One Test		1	1
		Aggregate crushing Value	One Test		1	1
		Aggregate Impact Value	One Test		1	1
4	Fine aggregate	SIEVE ANALYSIS	One Test		1	1
		Water Absorption	One Test		1	1
		Specific Gravity	One Test		1	1
		Material finer than 75 micron	One Test		1	1
5	Block(400*150*200)	BLOCK DENSITY	One Test		1	1
		WATER ABSORPTION	One Test		1	1
		DIMENSION ANALYSIS	One Test		1	1
		COMPRESSIVE STRENGTH	One Test		1	1
6	PCC(M15)	Compressive Strength(7days and 28days)	3 set /16-30 cum	16.15	6	6

S. S. S.



7	WMM	Sieve Analysis	One Test	1	1
		Impact Value	One Test	1	1
		Flakiness Index	One Test	1	1
		Elongation Index	One Test	1	1
8	BC	SIEVE ANALYSIS	One Test	1	1
		STRIPPING VALUE	One Test	1	1
		Flakiness Index	One Test	1	1
		Elongation Index	One Test	1	1
		IMPACT VALUE	One Test	1	1
		Specific gravity	One Test	1	1
		Water Absorption	One Test	1	1
		Marshal Stability	One Test	1	1
		Marshal flow	One Test	1	1
		Percent air Voids	One Test	1	1
		Percent Voids in mineral	One Test	1	1
		Percent Voids filled with Bitumen	One Test	1	1
		Density	One Test	1	1
		Gradation	One Test	1	1
9	BITUMEN	Ductility	One Test	1	1
		Softening Point	One Test	1	1
		Penetration	One Test	1	1
		Flash Point	One Test	1	1
		Fire Point	One Test	1	1
10	TACK COAT	Rate of spread	One Test	1	1
11	BM	SIEVE ANALYSIS	One Test	1	1
		STRIPPING VALUE	One Test	1	1
		Flakiness Index	One Test	1	1
		Elongation Index	One Test	1	1
		IMPACT VALUE	One Test	1	1
		Specific gravity	One Test	1	1
		Water Absorption	One Test	1	1
		Marshal Stability	One Test	1	1
		Marshal flow	One Test	1	1
		Percent air Voids	One Test	1	1
		Percent Voids in mineral	One Test	1	1
		Percent Voids filled with Bitumen	One Test	1	1
		Density	One Test	1	1
		Gradation	One Test	1	1

S. S. S.



AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

Format No: CP/TF/01

TEST REPORT OF PHYSICAL PROPERTIES OF CEMENT - 53 Grade

Lab ID : CP-2020-03-04-07 Date: 16-12-19
Customer : Assistant Executive Engineer, Vidyanarayapura Sub Division, BBMP, Bangalore.
Address : Vidyanarayapura Sub Division, BBMP, Bangalore.
Project Name : Improvements and Asphaltting to Roads at 6th Main Dhanalakshmi Layout in Ward No.09 (Vidyanarayapura) Vidyanarayapura Sub Division.
Agency : M/s. S.L.V Constructions Prop. Sri. Namith B #83, 1st Floor, 8th Main Road BEML Layout, Basaveshwaranagara Bangalore-560079.
Customer's Reference : BBMP/EE/BTP/WO/173/2019-20
Source of Sample : Sample supplied by Agency
Sample Condition : Satisfactory
Date of Receipt : 13-12-19
Sample Type : Birla Super 53grade
Reference to BIS codes : IS 12269 : 2013, 53 Grade Ordinary Portland cement Specification ,
IS 4031 (Part 1,2,3,4,5, 6,11):1988
IS 4031 Part 1 DETERMINATION OF FINENESS BY DRY SIEVING, Clause 4.4
IS 4031 Part 2, Determination of Fineness by Blaine Air Permeability Method, Clause 5
IS 4031 Part 3, Determination of Soundness, Clause 5, Clause 6
IS 4031 Part 4, Determination of Consistency of Standard Cement Paste, Clause 5
IS 4031 Part 5, Determination of Initial & Final Setting Time, Clause 5
IS 4031 Part 11, DETERMINATION OF DENSITY , Clause 6
Date of test : 14-12-19
Environmental Conditions during test : Temperature: 26°C
Humidity: 72%

Sl.No.	Physical properties	Results	Requirement as per IS 12269: 2013
1	Fineness by dry sieving (%)	1.76	—
2	Finess by Air permeability method (m ² /kg,Min)	292.1	225m ² /kg, Min
3	Density (gm/cc)	3.12	—
4	Standard Consistency (%)	28.0%	Not specified
5	Initial Setting time	155 minutes	Not less than 30 minutes
6	Final Setting time	260 minutes	Not more than 600 minutes
7	Soundness (Le Chatelier's Method)	2mm	Not more than 10 mm

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

Page 1/1
****End of Report****



FOR CIVIL Pro.

R. KARTHIK RECHAN
Authorized Signatory
Quality Manager

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL |
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Scanned by CamScanner

Format No: CP/TF/01

TEST REPORT OF PHYSICAL PROPERTIES OF CEMENT - 53 Grade

Lab ID : CP-2020-03-04-07 Date: 11-01-20

Customer : Assistant Executive Engineer, Vidyaranyapura Sub Division, BBMP, Bangalore.

Address : Vidyaranyapura Sub Division, BBMP, Bangalore.

Project Name : Improvements and Asphaltting to Roads at 6th Main Dhanalakshmi Layout in Ward No.09 (Vidyaranyapura) Vidyaranyapura Sub Division.

Agency : M/s. S.L.V Constructions Prop. Sri. Namith B #83, 1st Floor, 8th Main Road BEML Layout, Basaveshwaranagara Bangalore-560079.

Customer's Reference : BBMP/EE/BTP/WO/173/2019-20

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 13-12-19

Sample Type : Birla Super 53grade

Reference to BIS codes : IS 12269 : 2013, 53 Grade Ordinary Portland cement Specification ,
IS 4031 Part 4, Determination of Consistency of Standard Cement Paste, Clause 5
IS 4031 Part 6, Determination of Compressive Strength, Clause 6

Date of test : 14-12-19

Environmental Conditions during test : Temperature: 26°C
Humidity: 72%

Compressive Strength			
Sl.No.	Physical properties	Results	Requirement as per IS 12269: 2013
1	3 Days	28.5N/mm ²	Not less than 27 N/mm ²
2	7 Days	39.0N/mm ²	Not less than 37 N/mm ²
3	28 Days	58.5N/mm ²	Not less than 53 N/mm ²

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate




S. R. S.



FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
****End of Report****



Format No: CP/TF/01

TEST REPORT ON COARSE AGGREGATES

Lab ID : CP-2020-03-04-07 Date: 16-12-19
Customer : Assistant Executive Engineer, Vidyaranyapura Sub Division,
BBMP, Bangalore.
Address : Vidyaranyapura Sub Division, BBMP, Bangalore.
Project Name : Improvements and Asphaltting to Roads at 6th Main Dhanalakshmi
Layout in Ward No.09 (Vidyaranyapura) Vidyaranyapura Sub
Division.
Agency : M/s. S.L.V Constructions Prop. Sri. Namith B #83, 1st Floor, 8th
Main Road BEML Layout, Basaveshwaranagara Bangalore-560079.
Customer's Reference : BBMP/EE/BTP/WO/173/2019-20
Source of Sample : Sample supplied by Agency
Sample condition : Satisfactory
Date of Receipt : 13-12-19
Sample Type : 40mm down size coarse aggregate
Reference to BIS codes : IS: 383:2016 (Specification for Coarse and fine Aggregates)
IS: 2386 :1963(Part - 1,3,4) RA2011
IS 2386 Part 1: Particle Size and Shape
IS 2386 Part 3: Specific gravity, Density, Voids, Water Absorption
IS 2386 Part 4: Mechanical Properties
Date of test : 13-12-19

SIEVE ANALYSIS (PARTICLE SIZE DISTRIBUTION) OF 40MM DOWN COARSE AGGREGATE:

Total weight taken : 15000 grams

Sample No.	Sieve No.	Weight Retained in gms	Cumulative Weight Retained in gms	% Cumulative Weight Retained	% Passing	Required as per IS 383:2016
1	80 mm	0	0	0.0	100	100
2	40 mm	245	245	1.6	98.4	90-100
3	20 mm	7875	8120	54.1	45.9	30-70
4	10 mm	3899	12019	80.1	19.9	10-35
5	4.75 mm	2588	14607	97.4	2.6	0-5
6	Pan	393	15000	100.0	0	---

Page 1/2

Format No: CP/TF/01

TEST REPORT ON COARSE AGGREGATES

Lab ID

: CP-2020-03-04-07

Date: 16-12-19

PHYSICAL PROPERTIES

Sl.no	Tests	Result	Requirements as per IS:383-2016
1	Flakiness Index(%)	12.4	Combined Flakiness & Elongation Index Shall not Exceed 40% for Uncrushed & Crushed Aggregate
2	Elongation Index(%)	11.9	
3	Specific Gravity	2.64	—
4	Bulk Density(Loose) (Kg/l)	1.38	—
5	Bulk Density(Compacted) (Kg/l)	1.45	—
6	Water Absorption(%)	0.22	—

Note:

The results pertain to the samples received and tested.


All information furnished by Customer/Representative

Any correction in the report will make this report invalid

This report without prior written approval should not be reproduced or published in full or part.

Samples will be disposed after 90 days from the date of issue of test certificate

FOR CIVIL Pro.


R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 2/2

****End of Report****


S. S. S.



Format No: CP/TF/01

TEST REPORT ON COARSE AGGREGATES

Lab ID : CP-2020-03-04-07 **Date:** 16-12-19
Customer : Assistant Executive Engineer, Vidyananyapura Sub Division, BBMP, Bangalore.
Address : Vidyananyapura Sub Division, BBMP, Bangalore.
Project Name : Improvements and Asphaltting to Roads at 6th Main Dhanalakshmi Layout in Ward No.09 (Vidyananyapura) Vidyananyapura Sub Division.
Agency : M/s. S.L.V Constructions Prop. Sri. Namith B #83, 1st Floor, 8th Main Road BEML Layout, Basaveshwaranagara Bangalore-560079.
Customer Reference : BBMP/EE/BTP/WO/173/2019-20
Source of Sample : Sample supplied by Agency
Sample Condition : Satisfactory
Date of Receipt : 13-12-19
Sample Type/ Size : 20mm down size coarse aggregate
Reference to BIS codes : IS: 383:2016 (Specification for Coarse and fine Aggregates)
IS: 2386 :1963(Part - 1,3,4) RA2011
IS 2386 Part 1: Particle Size and Shape
IS 2386 Part 3: Specific gravity, Density, Voids, Water Absorption
IS 2386 Part 4: Mechanical Properties
Date of test : 13-12-19

SIEVE ANALYSIS (PARTICLE SIZE DISTRIBUTION) OF 20MM DOWN COARSE AGGREGATE:

Total weight taken : 5000 grams

Sample No.	Sieve No.	Weight Retained in gms	Cumulative Weight Retained in gms	% Cumulative Weight Retained	% Passing	Required as per IS 383:2016
1	40 mm	0	0	0	100	100
2	20 mm	298	298	6.0	94.0	90-100
3	10 mm	2645	2943	58.9	41.1	25-55
4	4.75 mm	1811	4754	95.1	4.9	0-10
5	Pan	246	5000	100	0	-

S. S. S.

Page-1/2



Format No: CP/TF/01

TEST REPORT ON COARSE AGGREGATES

Lab ID

: CP-2020-03-04-07

Date: 16-12-19

PHYSICAL PROPERTIES

Sl.no	Tests	Result	Requirements as per IS:383-2016
1	Flakiness Index(%)	8.9	Combined Flakiness & Elongation Index Shall not Exceed 40% for Uncrushed & Crushed Aggregate
2	Elongation Index(%)	11.4	
3	Specific Gravity	2.62	—
4	Bulk Density(Loose) (Kg/l)	1.42	—
5	Bulk Density(Compacted) (Kg/l)	1.48	—
6	Water Absorption(%)	0.35	—
7	Aggregate crushing Value(%)	24.8	Max 30% for Aggregates to be used in concrete for wearing Surface, In case Aggregate Crushing Value Exceeds 30% then the test for ten percent fines should be conducted for Aggregates to be used in concrete other than for wearing Surface.
8	Aggregate Impact Value(%)	25.1	30% for Aggregates to be used in concrete for wearing Surface, 45% for Aggregates to be used in concrete other than for wearing Surface.


Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate




R. Karthik Rechan



FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signature
Quality Manager

Page 2/2
End of Report



Format No: CP/TF/01

TEST REPORT OF FINE AGGREGATE

Lab ID : CP-2020-03-04-07 Date: 16-12-19

Customer : Assistant Executive Engineer, Vidyaranyapura Sub Division, BBMP, Bangalore.

Address : Vidyaranyapura Sub Division, BBMP, Bangalore.

Project Name : Improvements and Asphaltting to Roads at 6th Main Dhanalakshmi Layout in Ward No.09 (Vidyaranyapura) Vidyaranyapura Sub Division.

Agency : M/s. S.L.V Constructions Prop. Sri. Namith B #83, 1st Floor, 8th Main Road BEML Layout, Basaveshwaranagara Bangalore-560079.

Customer's Reference : BBMP/EE/BTP/WO/173/2019-20

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 13-12-19

Sample Type : Fine Aggregate

Reference to BIS codes : IS 383 : 2016 (Specification for Coarse and fine Aggregates)
IS: 2386 :1963(Part - 1, 3) RA2012
IS 2386 Part 1: Particle Size and Shape
IS 2386 Part 3: Specific gravity, Density, Voids, Water Absorption

Date of test : 13-12-19

Total weight taken : 1000 grams

Sl.no	Sieve Size	Weight Retained (gms)	Cumulative Weight Retained (gms)	% Cumulative Weight Retained	% Passing	Requirement as per IS 383:2016			
						Grading Zone I	Grading Zone II	Grading Zone III	Grading Zone IV
1	10 mm	0	0	0.0	100.0	100	100	100	100
2	4.75 mm	27	27	2.7	97.3	90-100	90-100	90-100	95-100
3	2.36 mm	55	82	8.2	91.8	60-95	75-100	85-100	95-100
4	1.18 mm	239	321	32.1	67.9	30-70	55-90	75-100	90-100
5	600 micron	205	526	52.6	47.4	15-34	35-59	60-79	80-100
6	300 micron	203	729	72.9	27.1	5-20	8-30	12-40	15-50
7	150 micron	191	920	92.0	8.0	0-10	0-10	0-10	0-15
8	Pan	80	1000	100.0	0.0	---	---	---	---

Result : The tested Sample Conforms to Grading Zone II

[Signature]

[Signature]
S. D. S.

Page 1/2

[Signature]



TEST REPORT OF FINE AGGREGATE

Lab ID

: CP-2020-03-04-07

Date: 16-12-19

PHYSICAL PROPERTIES

Sl.no	Tests	Result	Requirements as per IS 383:2016
1	Water Absorption(%)	1.5	—
2	Specific Gravity	2.59	—
3	Material finer than 75 micron(%)	6.9	Uncrushed fine Aggregate Max 3%, Crushed Fine aggregate Max 15%, Mixed Fine aggregate Max 12%, Manufactured Fine aggregate Max 10%

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate



FOR CIVIL Pro.


R. KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 2/2

****End of Report****


S. S. S.



Format No: CP/TF/01

TEST REPORT ON PHYSICAL REQUIREMENTS OF SOLID CONCRETE BLOCKS

Lab ID : CP-2020-03-04-07 Date: 26-12-19

Customer : Assistant Executive Engineer, Vidyananyapura Sub Division, BBMP, Bangalore.

Address : Vidyananyapura Sub Division, BBMP, Bangalore.

Project Name : Improvements and Asphaltting to Roads at 6th Main Dhanalakshmi Layout in Ward No.09 (Vidyananyapura) Vidyananyapura Sub Division.

Agency : M/s. S.L.V Constructions Prop. Sri. Namith B #83, 1st Floor, 8th Main Road BEML Layout, Basaveshwaranagara Bangalore-560079.

Customer's Reference : BBMP/EE/BTP/WO/173/2019-20

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 23-12-19

Sample Type/Size : Solid concrete blocks size (400X150X200)mm

Reference to BIS codes : IS : 2185 (Part 1) : 2005(RA 2010) Concrete Masonry Specification
Part 1:Hollow and Solid Concrete Blocks (Dimensions -Annex-B, Clause 9.2 and 10 , Block density Annex -C Clause 9.3 and 10, Compressive strength Annex -D Clause 9.4 and 10, Water absorption Annex -E Clause 9.5 and 10)

Date of test : 23-12-19

BLOCK DENSITY:

Sl. No.	Measurement of overall Dimensions of Individual Blocks			Overall Volume of the Block in Cubic Centimetres	Weight of Oven Dried Block in Kilograms to the nearest 10 Gram	Block Density in Kg/cum*10 ⁶	Avg. Block Density in (Kg/cum)	As per IS 2185(Part 1):2005 (RA 2010)
	Length	Breadth	Height					
	mm	mm	mm	(Cm ³)	Kg	Kg/m ³	Kg/m ³	
1	399	150	198	11850	33.944	2864.4	2789.7	Not less than 1800Kg/m ³
2	405	149	203	12250	33.519	2736.2		
3	404	151	200	12201	33.777	2768.4		

WATER ABSORPTION:

Sl. No.	Wet weight after water absorption	Dry weight (Oven dry)	Water Absorption	Avg. Water Absorption	As per IS 2185(Part 1):2005 (RA 2010)
	kg	kg	%	%	
1	33.91	32.25	4.89	4.25	Shall not be more than 10% by mass
2	33.57	32.14	4.28		
3	33.44	32.24	3.59		

Page 1/3



Lab ID

: CP-2020-03-04-07

Date: 26-12-19

DIMENSION ANALYSIS

SLno	Length mm	Breadth mm	Height mm	Requirement as per IS 2185(Part 1):2005
1	401	151	200	Length : $\pm 5\text{mm}$ Breadth : $\pm 3\text{mm}$ Height : $\pm 3\text{mm}$
2	399	151	200	
3	403	150	202	
4	401	151	200	
5	401	151	199	
6	400	151	201	
7	403	150	203	
8	403	150	202	
9	399	151	199	
10	402	150	201	
11	399	151	203	
12	404	150	203	
13	400	151	199	
14	401	150	202	
15	401	150	201	
16	400	150	199	
17	403	151	203	
18	403	151	203	
19	403	151	201	
20	399	150	199	
Average of 20	401	151	201	

Page 2/3





M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Lab ID : CP-2020-03-04-07

Date: 26-12-19

COMPRESSIVE STRENGTH:

Sl. No.	Size of solid block		Area	Failure Load	Compressive strength	Average Compressive strength
	Length	Breadth				
	mm	mm	(mm ²)	(KN)	N/mm ²	(N/mm ²)
1	400	151	60292	279.1	4.6	4.5
2	399	151	60207	258.8	4.3	
3	403	150	60575	259.1	4.3	
4	401	151	60415	289.8	4.8	
5	401	151	60455	287.2	4.8	
6	400	151	60271	264.3	4.4	
7	403	150	60556	278.0	4.6	
8	403	150	60520	257.9	4.3	

As per IS Requirements (Table 2, Clause 5.1, 5.2 and 9.4)

Compressive strength		
Grade	Minimum average	Minimum Individual units.
C (5.0)	5.00 N/mm ²	4.00 N/mm ²
C (4.0)	4.00 N/mm ²	3.20 N/mm ²

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

(Signature)

(Signature)
S. R. U.

Page 3/3
****End of Report****



FOR CIVIL Pro.
(Signature)
R. KARTHIK RECHAN
Authorized Signatory
Quality Manager



Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 25/12/2019

Lab ID : CP-2020-03-04-07
 Customer : Assistant Executive Engineer, Vidyanarayapura Sub Division, BBMP, Bangalore.
 Address : Vidyanarayapura Sub Division, BBMP, Bangalore.
 Project Name : Improvements and Asphaltting to Roads at 6th Main Dhanalakshmi Layout in Ward No.09 (Vidyanarayapura) Vidyanarayapura Sub Division.
 Agency : M/s. S.L.V Constructions Prop. Sri. Namith B #83, 1st Floor, 8th Main Road BEML Layout, Basaveshwaranagara Bangalore-560079.
 Customer's Reference : BBMP/EE/BTP/WO/173/2019-20
 Source of Sample : Sample supplied by Agency
 Sample Condition : Satisfactory
 Date of Receipt : 20-12-19
 Customer ID : PCC
 Sample Type /Size : 150X150X150 mm
 Sample grade/Age : M15 / 7 Days Compressive Strength
 Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 25/12/2019

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen	Cross sectional area	Weight of the sample	Failure Load	Compressive strength	Average Compressive Strength
					(mm)	(Sq.mm)	(kg)	(KN)	(N/mm ²)	(N/mm ²)
1	PCC	M15	18/12/2019	25/12/2019	150.03 X 151.68 X 151.56	22757	8.795	294.6	12.9	12.7
2	PCC	M15	18/12/2019	25/12/2019	150.99 X 151.80 X 150.29	22921	8.736	285.4	12.4	
3	PCC	M15	18/12/2019	25/12/2019	149.79 X 151.59 X 149.34	22707	8.259	287.3	12.7	

Note:

The results pertain to the samples received and tested.
 All information furnished by Customer/Representative
 Any correction in the report will make this report invalid
 This report without prior written approval should not be reproduced or published in full or part.
 Samples will be disposed after 90 days from the date of issue of test certificate

[Signature]

[Signature]
 A. S. S.



FOR CIVIL Pro.
[Signature]
 R KARTHIK RECHAN
 Authorized Signatory
 Quality Manager

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 15/01/2020

Lab ID : CP-2020-03-04-07
Customer : Assistant Executive Engineer, Vidyanarayapura Sub Division, BBMP, Bangalore.
Address : Vidyanarayapura Sub Division, BBMP, Bangalore.
Project Name : Improvements and Asphaltting to Roads at 6th Main Dhanalakshmi Layout in Ward No.09 (Vidyanarayapura) Vidyanarayapura Sub Division.
Agency : M/s. S.L.V Constructions Prop. Sri. Namith B #83, 1st Floor, 8th Main Road BEML Layout, Basaveshwaranagara Bangalore-560079.
Customer's Reference : BBMP/EE/BTP/WO/173/2019-20
Source of Sample : Sample supplied by Agency
Sample Condition : Satisfactory
Date of Receipt : 20-12-19
Customer ID : PCC
Sample Type /Size : 150X150X150 mm
Sample grade/Age : M15 / 28 Days Compressive Strength
Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 15/01/2020

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen	Cross sectional area	Weight of the sample	Failure Load	Compressive strength	Average Compressive Strength
					(mm)	(Sq.mm)	(kg)	(KN)	(N/mm ²)	(N/mm ²)
1	PCC	M15	18/12/2019	15/01/2020	151.91 X 149.81 X 149.33	22759	8.110	387.6	17.0	17.4
2	PCC	M15	18/12/2019	15/01/2020	150.57 X 149.38 X 151.27	22492	8.053	396.0	17.6	
3	PCC	M15	18/12/2019	15/01/2020	150.65 X 150.61 X 149.10	22689	8.361	395.6	17.4	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate





FOR CIVIL Pro.

R. KARTHIK RECHAN
Authorized Signatory
Quality Manager



Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : CP-2020-03-04-07 Date: 25/12/2019
Customer : Assistant Executive Engineer, Vidyanayapura Sub Division, BBMP, Bangalore.
Address : Vidyanayapura Sub Division, BBMP, Bangalore.
Project Name : Improvements and Asphaltting to Roads at 6th Main Dhanalakshmi Layout in Ward No.09 (Vidyanayapura) Vidyanayapura Sub Division.
Agency : M/s. S.L.V Constructions Prop. Sri. Namith B #83, 1st Floor, 8th Main Road BEML Layout, Basaveshwaranagara Bangalore-560079.
Customer's Reference : BBMP/EE/BTP/WO/173/2019-20
Source of Sample : Sample supplied by Agency
Sample Condition : Satisfactory
Date of Receipt : 20-12-19
Customer ID : PCC
Sample Type /Size : 150X150X150 mm
Sample grade/Age : M15 / 7 Days Compressive Strength
Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 25/12/2019

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen	Cross sectional area	Weight of the sample	Failure Load	Compressive strength	Average Compressive Strength
					(mm)	(Sq.mm)	(kg)	(KN)	(N/mm ²)	(N/mm ²)
1	PCC	M15	18/12/2019	25/12/2019	150.06 X 149.46 X 151.52	22427	8.795	276.2	12.3	12.7
2	PCC	M15	18/12/2019	25/12/2019	149.49 X 151.06 X 150.09	22581	8.736	292.8	13.0	
3	PCC	M15	18/12/2019	25/12/2019	150.40 X 149.10 X 149.65	22426	8.259	284.3	12.7	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate



FOR CIVIL Pro.
R. KARTHIK RECHAN
Authorized Signatory
Quality Manager

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 15/01/2020

Lab ID : CP-2020-03-04-07

Customer : Assistant Executive Engineer, Vidyaranyapura Sub Division, BBMP, Bangalore.

Address : Vidyaranyapura Sub Division, BBMP, Bangalore.

Project Name : Improvements and Asphaltting to Roads at 6th Main Dhanalakshmi Layout in Ward No.09 (Vidyaranyapura) Vidyaranyapura Sub Division.

Agency : M/s. S.L.V Constructions Prop. Sri. Namith B #83, 1st Floor, 8th Main Road BEML Layout, Basaveshwaranagara Bangalore-560079.

Customer's Reference : BBMP/EE/BTP/WO/173/2019-20

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 20-12-19

Customer ID : PCC

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M15 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 15/01/2020

Date of test					:		15/01/2020				
Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen	Cross sectional area	Weight of the sample	Failure Load	Compressive strength	Average Compressive Strength	
					(mm)	(Sq.mm)	(kg)	(KN)	(N/mm ²)	(N/mm ²)	
1	PCC	M15	18/12/2019	15/01/2020	151.66 X	22657	8.110	399.2	17.6	17.7	
					149.39 X						
					150.12						
2	PCC	M15	18/12/2019	15/01/2020	149.83 X	22658	8.053	401.9	17.7		
					151.23 X						
					150.45						
3	PCC	M15	18/12/2019	15/01/2020	149.31 X	22427	8.361	400.7	17.9		
					150.20 X						
					151.55						

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate



FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 25/12/2019

Lab ID : CP-2020-03-04-07
Customer : Assistant Executive Engineer, Vidyaranyapura Sub Division, BBMP, Bangalore.
Address : Vidyaranyapura Sub Division, BBMP, Bangalore.
Project Name : Improvements and Asphaltting to Roads at 6th Main Dhanalakshmi Layout in Ward No.09 (Vidyaranyapura) Vidyaranyapura Sub Division.
Agency : M/s. S.L.V Constructions Prop. Sri. Namith B #83, 1st Floor, 8th Main Road BEML Layout, Basaveshwaranagara Bangalore-560079.
Customer's Reference : BBMP/EE/BTP/WO/173/2019-20
Source of Sample : Sample supplied by Agency
Sample Condition : Satisfactory
Date of Receipt : 20-12-19
Customer ID : PCC
Sample Type /Size : 150X150X150 mm
Sample grade/Age : M15 / 7 Days Compressive Strength
Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 25/12/2019

Date of test					: 25/12/2019						
Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen	Cross sectional area	Weight of the sample	Failure Load	Compressive strength	Average Compressive Strength	
					(mm)	(Sq.mm)	(kg)	(KN)	(N/mm ²)	(N/mm ²)	
1	PCC	M15	18/12/2019	25/12/2019	149.30 X	22329	8.795	268.5	12.0	12.2	
					149.55 X						
					150.38						
2	PCC	M15	18/12/2019	25/12/2019	151.46 X	22913	8.736	276.7	12.1		
					151.28 X						
					149.22						
3	PCC	M15	18/12/2019	25/12/2019	149.72 X	22736	8.259	281.3	12.4		
					151.85 X						
					151.21						

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

[Signature]

[Signature]
J. S. M.

Page 1/1

****End of Report****



FOR CIVIL Pro.
[Signature]
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 15/01/2020

Lab ID : CP-2020-03-04-07

Customer : Assistant Executive Engineer, Vidyananyapura Sub Division, BBMP, Bangalore.

Address : Vidyananyapura Sub Division, BBMP, Bangalore.

Project Name : Improvements and Asphaltting to Roads at 6th Main Dhanalakshmi Layout in Ward No.09 (Vidyananyapura) Vidyananyapura Sub Division.

Agency : M/s. S.L.V Constructions Prop. Sri. Namith B #83, 1st Floor, 8th Main Road BEML Layout, Basaveshwaranagara Bangalore-560079.

Customer's Reference : BBMP/EE/BTP/WO/173/2019-20

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 20-12-19

Customer ID : PCC

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M15 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 15/01/2020

Date of test					: 15/01/2020						
Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen	Cross sectional area	Weight of the sample	Failure Load	Compressive strength	Average Compressive Strength	
					(mm)	(Sq.mm)	(kg)	(KN)	(N/mm ²)	(N/mm ²)	
1	PCC	M15	18/12/2019	15/01/2020	151.30 X	22695	8.110	402.6	17.7	17.4	
					150.00 X						
					150.23						
2	PCC	M15	18/12/2019	15/01/2020	150.67 X	22598	8.053	389.8	17.2		
					149.99 X						
					150.56						
3	PCC	M15	18/12/2019	15/01/2020	150.11 X	22811	8.361	392.4	17.2		
					151.96 X						
					151.41						

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

[Signature]

[Signature]
S. K. R.

Page 1/1

****End of Report****



FOR CIVIL PRO.
[Signature]
R KARTHIK RECHAN
Authorized Signatory
Quality Manager



TEST RESULTS OF GRADATION FOR WMM

Lab ID : CP-RW-2020-03-04-07 Date: 23-12-19
Customer : Assistant Executive Engineer, Vidyanarayapura Sub Division, BBMP, Bangalore.
Address : Vidyanarayapura Sub Division, BBMP, Bangalore.
Project Name : Improvements and Asphaltting to Roads at 6th Main Dhanalakshmi Layout in Ward No.09 (Vidyanarayapura) Vidyanarayapura Sub Division.
Agency : M/s. S.L.V Constructions Prop. Sri. Namith B #83, 1st Floor, 8th Main Road BEML Layout, Basaveshwaranagara Bangalore-560079.
Customer Reference : BBMP/EE/BTP/WO/173/2019-20
Source of Sample : Sample supplied by Agency
Sample Condition : Satisfactory
Date of Receipt : 21-12-19
Type of Mix : WMM (Wet Mix Macadam)
Date of test : 21-12-19
Oven Dry Weight : 11000 Grams

IS Sieve Size(mm)	Weight Retained (gm)	Cumulative Weight Retained (gm)	% Cumulative Weight Retained	% Passing	Spec.I.Vide Table 400.13 MORTH Specification
53	0	0	0.0	100.0	100
45	315	315	2.9	97.1	95-100
22.4	2259	2574	23.4	76.6	60-80
11.2	2179	4753	43.2	56.8	40-60
4.75	2251	7004	63.7	36.3	25-40
2.36	1621	8625	78.4	21.6	15-30
0.6	623	9248	84.1	15.9	8-22
0.075	1338	10586	96.2	3.8	0-5

Note:-

The results pertain to the samples received and tested.

All information Furnished by Customer/ Representative

Any correction in the report will make this report invalid.

This report without prior written approval should not be reproduced or published in full or part.

Samples will be disposed after 90 days from the date of issue of test certificate



FOR CIVIL PRO,
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
End of Report



TEST REPORT OF AGGREGATE IMPACT VALUE

IS: 2386 Part IV

Lab ID : CP-RW-2020-03-04-07 Date: 23-12-19
Customer : Assistant Executive Engineer, Vidyaranyapura Sub Division, BBMP, Bangalore.
Address : Vidyaranyapura Sub Division, BBMP, Bangalore.
Project Name : Improvements and Asphaltting to Roads at 6th Main Dhanalakshmi Layout in Ward No.09 (Vidyaranyapura) Vidyaranyapura Sub Division.
Agency : M/s. S.L.V Constructions Prop. Sri. Namith B #83, 1st Floor, 8th Main Road BEML Layout, Basaveshwaranagara Bangalore-560079.
Customer Reference : BBMP/EE/BTP/WO/173/2019-20
Source of Sample : Sample supplied by Agency
Sample Condition : Satisfactory
Date of Receipt : 21-12-19
Type of Mix : Coarse Aggregate for WMM (Wet Mix Macadam)
Date of test : 21-12-19

SLNo	Particulars of observations	Index	TEST 1	TEST 2
1	Total weight of the surface dry sample sample (passing 12.5 mm and retained on 10mm sieve)	A	300.2	300.2
2	Weight of fraction passing 2.36mm sieve After giving 15 blows	B	73.9	74.0
3	weight of fraction retained 2.36mm sieve After giving 15 blows	C	225.9	225.8
4	Total weight of (B+C) is less than the initial weight (Weight A) by more than one gram the result shall be discarded and a fresh test made.	A-(B+C)	0.4	0.4
5	Aggregate impact value	(B/A)*100	24.6	24.7
6	Aggregate impact value (Mean of two tests)	Percentage	24.6	

Note:-

The results pertain to the samples received and tested.
All information Furnished by Customer/ Representative
Any correction in the report will make this report invalid.
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate



FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
End of Report



AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

DETERMINATION OF FLAKINESS INDEX AND ELONGATION INDEX OF COARSE AGGREGATE (IS 2386 (Part 1) 1963 (RA 2007))

Lab ID : CP-RW-2020-03-04-07 Date: 23-12-19
Customer : Assistant Executive Engineer, Vidyananyapura Sub Division, BBMP, Bangalore.
Address : Vidyananyapura Sub Division, BBMP, Bangalore.
Project Name : Improvements and Asphaltting to Roads at 6th Main Dhanalakshmi Layout in Ward No.09 (Vidyananyapura) Vidyananyapura Sub Division.
Agency : M/s. S.L.V Constructions Prop. Sri. Namith B #83, 1st Floor, 8th Main Road BEML Layout, Basaveshwaranagara Bangalore-560079.
Customer Reference : BBMP/EE/BTP/WO/173/2019-20
Source of Sample : Sample supplied by Agency
Sample Condition : Satisfactory
Date of Receipt : 21-12-19
Type of Mix : Coarse Aggregate for WMM (Wet Mix Macadam)
Date of test : 21-12-19

Result:

Index	Percentage of Flakiness and Elongation Index	Secified limits as per MORTH specification table 400-12
Flakiness Index	12.8%	Combined Flakiness & Elongation Index for WMM is Maximum 35%
Elongation Index	12.5%	
Combined Flakiness and Elongation Index for WMM	25.3%	

Note:-

The results pertain to the samples received and tested.
All information Furnished by Customer/ Representative
Any correction in the report will make this report invalid.
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

S. S. S.



FOR CIVIL Pro.

R. KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
End of Report

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Lab ID

Customer

Address

Project Name

Agency

Customer's Reference

Source of Sample

Sample Condition

Date of Receipt

Sample Type

Reference to BIS codes

Date of test

Test Results

TEST REPORT ON BITUMEN

CP-RW-2020-03-04-07

Assistant Executive Engineer, Vidyaranyapura Sub Division, BBMP, Bangalore.

Vidyaranyapura Sub Division, BBMP, Bangalore.

Improvements and Asphaltting to Roads at 6th Main Dhanalakshmi Layout in Ward No.09 (Vidyaranyapura) Vidyaranyapura Sub Division.

M/s. S.L.V Constructions Prop. Sri. Namith B #83, 1st Floor, 8th Main Road BEML Layout, Basaveshwaranagara Bangalore-560079.

BBMP/EE/BTP/WO/173/2019-20

Sample supplied by Agency

Satisfactory

30-12-19

Bitumen

IS: 1201-1220(1978) (Reaffirmed-2004)

30-12-19

Format No: CP/TF/01

Date: 31-12-19

Sl.no	Name of Test	Result	Requirements as per IS:73-2013
1	Penetration at 25°C, in 1/10th mm		
2	Softening Point, °C	64	60 to 70
3	Ductility, cm	51.2	Min. 40°C
4	Flash point, °C	98	Min. 75cm
	Fire point, °C	246	
		272	Min. 220°C

Note:-

The results pertain to the samples received and tested.

All information Furnished by Customer/ Representative

Any correction in the report will make this report invalid.

This report without prior written approval should not be reproduced or published in full or part.

Samples will be disposed after 90 days from the date of issue of test certificate

[Signature]

[Signature]
S. S. S.



FOR CIVIL Pro.

[Signature]
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1

****End of Report****



TEST RESULTS OF GRADATION FOR BM (IS 2386:(Part 1) 1963 (RA2011))

Lab ID : CP-RW-2020-03-04-07 Date: 06-01-20
Customer : Assistant Executive Engineer, Vidyananyapura Sub Division, BBMP, Bangalore.
Address : Vidyananyapura Sub Division, BBMP, Bangalore.
Project Name : Improvements and Asphaltting to Roads at 6th Main Dhanalakshmi Layout in Ward No.09 (Vidyananyapura) Vidyananyapura Sub Division.
Agency : M/s. S.L.V Constructions Prop. Sri. Namith B #83, 1st Floor, 8th Main Road BEML Layout, Basaveshwaranagara Bangalore-560079.
Customer Reference : BBMP/EE/BTP/WO/173/2019-20
Source of Sample : Sample supplied by Agency
Sample Condition : Satisfactory
Date of Receipt : 03-01-20
Type of Mix : BM-Plant (Bituminous Macadam)
Date of test : 03-01-20
Weight of Sample(gm) : 5000

IS Sieve Size(mm)	Weight Retained(gm)	Cumulative Weight Retained (gm)	Cumulative % of Retained	Cumulative % of Passing	Specification Limits as per MORTH specification Table 500-7(grading -2)
26.5	0	0	0	100	100
19	165	165	3.3	96.7	90-100
13.2	512	677	13.5	86.5	56-88
4.75	2759	3436	68.7	31.3	16-36
2.36	911	4347	86.9	13.1	4-19
0.3	358	4705	94.1	5.9	2-10
0.075	232	4937	98.7	1.3	0-8
PAN	63	5000	100.0	0.0	0

Note:-

The results pertain to the samples received and tested.

All information Furnished by Customer/ Representative

Any correction in the report will make this report invalid.

This report without prior written approval should not be reproduced or published in full or part.

Samples will be disposed after 90 days from the date of issue of test certificate



FOR CIVIL PRO
R.KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
End of Report



AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

PHYSICAL REQUIREMENTS FOR COARSE AGGREGATE FOR BITUMINOUS MACADAM

Lab ID : CP-RW-2020-03-04-07 Date: 06-01-20
Customer : Assistant Executive Engineer, Vidyaranyapura Sub Division, BBMP, Bangalore.
Address : Vidyaranyapura Sub Division, BBMP, Bangalore.
Project Name : Improvements and Asphaltting to Roads at 6th Main Dhanalakshmi Layout in Ward No.09 (Vidyaranyapura) Vidyaranyapura Sub Division.
Agency : M/s. S.L.V Constructions Prop. Sri. Namith B #83, 1st Floor, 8th Main Road BEML Layout, Basaveshwaranagara Bangalore-560079.
Customer Reference : BBMP/EE/BTP/WO/173/2019-20
Source of Sample : Sample supplied by Agency
Sample Condition : Satisfactory
Date of Receipt : 03-01-20
Type of Mix : BM (Bituminous Macadam)
Date of test : 03-01-20

Table 500-6 : Physical Requirements for Coarse Aggregate for Bituminous Macadam

Property	Test	Result	Specification	Method of Test
Partical Shape	Flakiness Index	13.8	Combined Flakiness & Elongation Index for BM is Maximum 35%	IS:2386 Part I
	Elongation Index	7.2		
Strength	Aggregate Impact Value	25.2	Maximum 30%	IS:2386 Part IV
Specific gravity	Specific gravity	2.51	Maximum 2.7	IS:2386 Part III
Water Absorption	Water Absorption	0.17	Maximum 2%	IS:2386 Part III

Note:-

The results pertain to the samples received and tested.
All information Furnished by Customer/ Representative
Any correction in the report will make this report invalid.
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate



FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
End of Report

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Scanned by CamScanner

TEST REPORT OF AGGEGRATE STRIPPING VALUE OF ROAD AGGRGATE (IS:6241)

Lab ID : CP-RW-2020-03-04-07 Date: 06-01-20
Customer : Assistant Executive Engineer, Vidyaranyapura Sub Division, BBMP, Bangalore.
Address : Vidyaranyapura Sub Division, BBMP, Bangalore.
Project Name : Improvements and Asphaltting to Roads at 6th Main Dhanalakshmi Layout in Ward No.09 (Vidyaranyapura) Vidyaranyapura Sub Division.
Agency : M/s. S.L.V Constructions Prop. Sri. Namith B #83, 1st Floor, 8th Main Road BEML Layout, Basaveshwaranagara Bangalore-560079.
Customer Reference : BBMP/EE/BTP/WO/173/2019-20
Source of Sample : Sample supplied by Agency
Sample Condition : Satisfactory
Date of Receipt : 03-01-20
Type of Mix : BM(Bitumnous Macadam)
Date of test : 03-01-20
Type of Binder : 60/70
% of Binder Used : 5.0%
Weight of Aggregate : 200.0 gm
Weight of Binder : 10.0 gm
Temperature of water bath : 40°C

No of test	Retained Stripping Percentage	Stripping Percentage	Average Retained Stripping Percentage	Secified limits as per MORTH specification table 500-8
1	98.0	2.0	98.2	Minimum Retained Coating 95%
2	98.5	1.5		
3	98.0	2.0		

Note:-
The results pertain to the samples received and tested.
All information Furnished by Customer/ Representative
Any correction in the report will make this report invalid.
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate





FOR CIVIL Pro.

R. KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1

****End of Report****

TESTS RESULTS ON STABILITY OF MIX

Lab ID : CP-RW-2020-03-04-07 Date: 06-01-20
Customer : Assistant Executive Engineer, Vidyanayapura Sub Division, BBMP, Bangalore.
Address : Vidyanayapura Sub Division, BBMP, Bangalore.
Project Name : Improvements and Asphaltting to Roads at 6th Main Dhanalakshmi Layout in Ward No.09 (Vidyanayapura) Vidyanayapura Sub Division.
Agency : M/s. S.L.V Constructions Prop. Sri. Namith B #83, 1st Floor, 8th Main Road BEML Layout, Basaveshwaranagara Bangalore-560079.
Customer Reference : BBMP/EE/BTP/WO/173/2019-20
Source of Sample : Hot Mix Plant, Bangalore
Sample Condition : Satisfactory
Date of Receipt : 03-01-20
Type of Mix : BM (Bituminous Mecadam)
Date of test : 03-01-20

The results of the tests conducted on the Bituminous Macadam mix sample are as follow

Sl.No	Particulars of observations	TEST 1	TEST 2	Secified limits as per MORTH specification table 500-11
1	Marshal Stability at 60°C, KN	11.29	11.82	9KN(Min)
2	Marshal flow at 60°C, mm	3.54	3.87	2-4
3	Percent air Voids	4.56	4.17	3-5
4	Percent Voids in mineral Aggregate(VMA %)	14.54	14.76	13-15
5	Percent Voids filled with Bitumen(VFB %)	68.98	70.28	65-75
6	Density, g/cc	2.42	2.40	-

Note:-

The results pertain to the samples received and tested.

All information Furnished by Customer/ Representative

Any correction in the report will make this report invalid.

This report without prior written approval should not be reproduced or published in full or part.

Samples will be disposed after 90 days from the date of issue of test certificate



FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
End of Report

TEST RESULTS OF BITUMEN BINDAR CONTENT AND GRADATION FOR BM (IS 2386:(Part 1) 1963 (RA2011))

Lab ID : CP-RW-2020-03-04-07 Date: 17-01-20

Customer : Assistant Executive Engineer, Vidyanayapura Sub Division, BBMP, Bangalore.

Address : Vidyanayapura Sub Division, BBMP, Bangalore.

Project Name : Improvements and Asphaltting to Roads at 6th Main Dhanalakshmi Layout in Ward No.09 (Vidyanayapura) Vidyanayapura Sub Division.

Agency : M/s. S.L.V Constructions Prop. Sri. Namith B #83, 1st Floor, 8th Main Road BEML Layout, Basaveshwaranagara Bangalore-560079.

Customer Reference : BBMP/EE/BTP/WO/173/2019-20

Source of Sample : Sample supplied by Agency

Date of Receipt : 16-01-20

Type of Mix : BM (Bituminous Macadam)

Date of test : 16-01-20

Sl.no	Description	Index	Trail 1	Trail 2
1	Weight of the Sample	A	500	500
2	Weight of the sample After extraction	B	467.5	466.5
3	Bitumen percentage	$\frac{A-B}{A} \times 100$	6.5	6.70
4	Average percentage	%	6.60	




S. S. S.

Page 1/2



FOR CIVIL Pro.


R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Lab ID

: CP-RW-2020-03-04-07

Date: 17-01-20

AFTER EXTRACTION(Trail-1)

Weight of Sample : 467.5 Grams

IS Sieve Size(mm)	Weight Retained (gm)	Cumulative Weight Retained (gm)	Cumulative % of Retained	Cumulative % of Passing	Specification Limits as per MORTH specification Table 500-7(grading -2)
26.5	0	0	0.0	100.0	100
19	38	38	8.1	91.9	90-100
13.2	147	185	39.6	60.4	56-88
4.75	191	376	80.4	19.6	16-36
2.36	28	404	86.4	13.6	4-19
0.3	32	436	93.3	6.7	2-10
0.075	20	456	97.5	2.5	0-8

AFTER EXTRACTION(Trail-2)

Weight of Sample : 466.5 Grams

IS Sieve Size(mm)	Weight Retained (gm)	Cumulative Weight Retained (gm)	Cumulative % of Retained	Cumulative % of Passing	Specification Limits as per MORTH specification Table 500-7(grading -2)
26.5	0	0	0.0	100.0	100
19	38	38	8.1	91.9	90-100
13.2	147	185	39.7	60.3	56-88
4.75	191	376	80.6	19.4	16-36
2.36	28	404	86.6	13.4	4-19
0.3	32	436	93.5	6.5	2-10
0.075	25	461	98.8	1.2	0-8

Note:-

The results pertain to the samples received and tested.
All information Furnished by Customer/ Representative
Any correction in the report will make this report invalid.
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate




Page 2/2
End of Report



FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager



TEST RESULTS OF GRADATION FOR BC IS 2386 (Part 1) 1963 (RA 2007)

Lab ID : CP-RW-2020-03-04-07 Date: 11-01-20
Customer : Assistant Executive Engineer, Vidaranyapura Sub Division, BBMP, Bangalore.
Address : Vidaranyapura Sub Division, BBMP, Bangalore.
Project Name : Improvements and Asphaltting to Roads at 6th Main Dhanalakshmi Layout in Ward No.09 (Vidaranyapura) Vidaranyapura Sub Division.
Agency : M/s. S.L.V Constructions Prop. Sri. Namith B #83, 1st Floor, 8th Main Road BEML Layout, Basaveshwaranagara Bangalore-560079.
Customer Reference : BBMP/EE/BTP/WO/173/2019-20
Source of Sample : Sample supplied by Agency
Sample Condition : Satisfactory
Date of Receipt : 09-01-20
Type of Mix : BC-Plant (Bituminous Concrete)
Date of test : 09-01-20
Oven Dry Weight : 5000 Grams

IS Sieve Size (mm)	Weight Retained (gm)	Cumulative Weight Retained (gm)	Cumulative % of Retained	Cumulative % of Passing	Secified limits as per MORTH specification table 500-17(grading-2)
19	0	0	0.0	100.0	100
13.2	89	89	1.8	98.2	90-100
9.5	702	791	15.8	84.2	70-88
4.75	895	1686	33.7	66.3	53-71
2.36	587	2273	45.5	54.5	42-58
1.18	492	2765	55.3	44.7	34-48
0.6	503	3268	65.4	34.6	26-38
0.3	528	3796	75.9	24.1	18-28
0.15	458	4254	85.1	14.9	12-20
0.075	350	4604	92.1	7.9	4-10
PAN	396	5000	100	0.0	0

Note:-

The results pertain to the samples received and tested.
All information Furnished by Customer/ Representative
Any correction in the report will make this report invalid.
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

Page 1/1
End of Report



FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager



AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

TEST REPORT OF AGGREGATE STRIPPING VALUE OF ROAD AGGREGATE (IS:6241)

Lab ID : CP-RW-2020-03-04-07 Date: 13-01-20
Customer : Assistant Executive Engineer, Vidyanarayapura Sub Division, BBMP, Bangalore.
Address : Vidyanarayapura Sub Division, BBMP, Bangalore.
Project Name : Improvements and Asphaltting to Roads at 6th Main Dhanalakshmi Layout in Ward No.09 (Vidyanarayapura) Vidyanarayapura Sub Division.
Agency : M/s. S.L.V Constructions Prop. Sri. Namith B #83, 1st Floor, 8th Main Road BEML Layout, Basaveshwaranagara Bangalore-560079.
Customer Reference : BBMP/EE/BTP/WO/173/2019-20
Source of Sample : Sample supplied by Agency
Sample Condition : Satisfactory
Date of Receipt : 09-01-20
Type of Mix : BC(Bitumenous Concrete)
Date of test : 09-01-20

Type of Binder : 60/70
% of Binder Used : 5.0%
Weight of Aggregate : 200.0 gm
Weight of Binder : 10.0 gm
Temperature of water bath : 40°C

No of test	Retained Stripping Percentage	Stripping Percentage	Average Retained Stripping Percentage	Secified limits as per MORTH specification table 500-8
1	98.5	1.5	98.3	Minimum Retained Coating 95%
2	98.5	1.5		
3	98.0	2.0		

Note:-

The results pertain to the samples received and tested.
All information Furnished by Customer/ Representative
Any correction in the report will make this report invalid.
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate



FOR CIVIL Pro.
R. KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Scanned by CamScanner



PHYSICAL REQUIREMENTS FOR COARSE AGGREGATE FOR BITUMINOUS CONCRETE

Lab ID : CP-RW-2020-03-04-07
Customer : Assistant Executive Engineer, Vidyanarayapura Sub Division, BBMP, Bangalore. **Date: 13-01-20**
Address : Vidyanarayapura Sub Division, BBMP, Bangalore.
Project Name : Improvements and Asphaltting to Roads at 6th Main Dhanalakshmi Layout in Ward No.09 (Vidyanarayapura) Vidyanarayapura Sub Division.
Agency : M/s. S.L.V Constructions Prop. Sri. Namith B #83, 1st Floor, 8th Main Road BEML Layout, Basaveshwaranagara Bangalore-560079.
Customer Reference : BBMP/EE/BTP/WO/173/2019-20
Source of Sample : Sample supplied by Agency
Sample Condition : Satisfactory
Date of Receipt : 09-01-20
Type of Mix : BC (Bituminous Concrete)
Date of test : 09-01-20

Table 500-16 : Physical Requirements fo Coarse Aggregate for Bituminous Concrete

Property	Test	Result	Specification	Method of Test
Partical Shape	Flakiness Index	12.4	Combined Flakiness & Elongation Index for BC is Maximum 35%	IS:2386 Part I
	Elongation Index	11.8		
Strength	Aggregate Impact Value	22.1	Maximum 24%	IS:2386 Part IV
Specific gravity	Specific gravity	2.68	Maximum 2.7	IS:2386 Part III
Water Absorption	Water Absorption	0.21	Maximum 2%	IS:2386 Part III

Note:-

The results pertain to the samples received and tested.

All information Furnished by Customer/ Representative

Any correction in the report will make this report invalid.

This report without prior written approval should not be reproduced or published in full or part.

Samples will be disposed after 90 days from the date of issue of test certificate

S. S. S.

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

TESTS RESULTS ON STABILITY OF MIX

Lab ID : CP-RW-2020-03-04-07 **Date:** 13-01-20

Customer : Assistant Executive Engineer, Vidyaranyapura Sub Division, BBMP, Bangalore.

Address : Vidyaranyapura Sub Division, BBMP, Bangalore.

Project Name : Improvements and Asphaltting to Roads at 6th Main Dhanalakshmi Layout in Ward No.09 (Vidyaranyapura) Vidyaranyapura Sub Division.

Agency : M/s. S.L.V Constructions Prop. Sri. Namith B #83, 1st Floor, 8th Main Road BEML Layout, Basaveshwaranagara Bangalore-560079.

Customer Reference : BBMP/EE/BTP/WO/173/2019-20

Source of Sample : Hot Mix Plant, Bangalore

Sample Condition : Satisfactory

Date of Receipt : 09-01-20

Type of Mix : BC (Bituminous Concrete)

Date of test : 09-01-20

The results of the tests conducted on the Bituminous Concrete mix sample are as follow				
Sl.No	Particulars of observations	TEST 1	TEST 2	Secified limits as per MORTH specification table 500-11
1	Marshal Stability at 60°C, KN	11.14	11.13	10KN(min)
2	Marshal flow at 60°C, mm	3.52	3.51	2-4
3	Percent air Voids	4.82	4.83	3-5
4	Percent Voids in mineral Aggregate(VMA %)	14.28	14.26	13-15
5	Percent Voids filled with Bitumen(VFB %)	71.87	71.63	65-75
6	Density, g/cc	2.25	2.26	—

Note:-

The results pertain to the samples received and tested.
 All information Furnished by Customer/ Representative
 Any correction in the report will make this report invalid.
 This report without prior written approval should not be reproduced or published in full or part.
 Samples will be disposed after 90 days from the date of issue of test certificate

S. S. S.

Page 1/1
End of Report



FOR CIVIL Pro.
R KARTHIK RECHAN
 Authorized Signatory
 Quality Manager

TEST RESULTS OF BITUMEN BINDAR CONTENT AND GRADATION FOR BC IS 2386 (Part 1) 1963 (RA 2011)

Lab ID : CP-RW-2020-03-04-07 Date: 22-01-20
Customer : Assistant Executive Engineer, Vidyaranyapura Sub Division, BBMP, Bangalore.
Address : Vidyaranyapura Sub Division, BBMP, Bangalore.
Project Name : Improvements and Asphaltting to Roads at 6th Main Dhanalakshmi Layout in Ward No.09 (Vidyaranyapura) Vidyaranyapura Sub Division.
Agency : M/s. S.L.V Constructions Prop. Sri. Namith B #83, 1st Floor, 8th Main Road BEML Layout, Basaveshwaranagara Bangalore-560079.
Customer Reference : BBMP/EE/BTP/WO/173/2019-20
Source of Sample : Sample supplied by Agency
Date of Receipt : 20-01-20
Type of Mix : BC (Bituminous Concrete)
Date of test : 20-01-20

Sl.no	Description	Index	Trail 1	Trail 2
1	Weight of the Sample	A	500	500
2	Weight of the sample After extraction	B	470	469
3	Bitumen percentage	$\frac{A-B}{A} \times 100$ A	6.00	6.20
4	Average percentage	%	6.1	



FOR CIVIL Pro.

[Signature]
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/2

Lab ID : CP-RW-2020-03-04-07

Date: 22-01-20

AFTER EXTRACTION - Trail-1

Total Weight of the Sample(gm) : 470

IS Sieve Size (mm)	Weight Retained (gm)	Cumulative Weight Retained (gm)	Cumulative % of Retained	Cumulative % of Passing	Secified limits as per MORTH specification table 500-23(grading-2)
19	0	0	0.0	100.0	100
13.2	4	4	0.9	99.1	90-100
9.5	62	66	14.0	86.0	70-88
4.75	112	178	37.9	62.1	53-71
2.36	88	266	56.6	43.4	42-58
1.18	29	295	62.8	37.2	34-48
0.6	11	306	65.1	34.9	26-38
0.3	46	352	74.9	25.1	18-28
0.15	45	397	84.5	15.5	12-20
0.075	48	445	94.7	5.3	4-10

AFTER EXTRACTION - Trail-2

Total Weight of the Sample(gm) : 469

IS Sieve Size (mm)	Weight Retained (gm)	Cumulative Weight Retained (gm)	Cumulative % of Retained	Cumulative % of Passing	Secified limits as per MORTH specification table 500-23(grading-2)
19	0	0	0.0	100.0	100
13.2	4	4	0.9	99.1	90-100
9.5	62	66	14.1	85.9	70-88
4.75	112	178	38.0	62.0	53-71
2.36	88	266	56.7	43.3	42-58
1.18	29	295	62.9	37.1	34-48
0.6	11	306	65.2	34.8	26-38
0.3	46	352	75.1	24.9	18-28
0.15	45	397	84.6	15.4	12-20
0.075	50	447	95.3	4.7	4-10

Note:-

The results pertain to the samples received and tested.
All information Furnished by Customer/ Representative
Any correction in the report will make this report invalid.
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

S. S. S.
End of Report



FOR CIVIL-Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

DETERMINATION OF RATE OF SPREAD TACK COAT

Lab ID : CP-RW-2020-03-04-07 **Date:** 21-01-20

Customer : Assistant Executive Engineer, Vidyanarayapura Sub Division, BBMP, Bangalore.

Address : Vidyanarayapura Sub Division, BBMP, Bangalore.

Project Name : Improvements and Asphaltting to Roads at 6th Main Dhanalakshmi Layout in Ward No.09 (Vidyanarayapura) Vidyanarayapura Sub Division.

Agency : M/s. S.L.V Constructions Prop. Sri. Namith B #83, 1st Floor, 8th Main Road BEML Layout, Basaveshwaranagara Bangalore-560079.

Customer Reference : BBMP/EE/BTP/WO/173/2019-20

Sample Condition : Satisfactory

Date of Receipt : 20-01-20

Type of Mix : Tack coat

Date of test : 20-01-20

SLNo	Determination	Unit	TEST 1	TEST 2
1	Size of Plate (mxm)	Mt	0.30 x .30	0.30 x .30
2	Area of Plate (a)	Sq.mtr	0.09	0.09
3	Initial Wt of empty Plate (b)	Kg	0.74	0.744
4	Final weight of plate after application of tack Coat (c)	Kg	0.763	0.767
5	Weight of tack Coat (d=c-b)	Kg	0.023	0.023
6	Rate of spread of tack coat	Kg/sq.m	0.256	0.256
7	Average	Kg/sq.m	0.256	
8	Specified Limit	Kg/sq.m	0.250 Kg/sq.m	

Note:-

The results pertain to the samples received and tested.
All information Furnished by Customer/ Representative
Any correction in the report will make this report invalid.
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate



FOR CIVIL Pro.

KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
End of Report